

N.B. Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as cancelled.

Signature Not Verified
Digitally signed by PANDIT
Date: 2023.04.27 12:13:27 IST

Director
West Bengal Fire & Emergency Services

Lobbies etc. and other places of assembly of the building in case of normal power failure.

DETECTION AND ALARM SYSTEM:

1. Manually operated Electrical Fire Alarm System with at least three numbers of break glass type call boxes fitted with Hooters along with Public Address System at each floor connecting with visual panel board shall be made in Control Room. The Control Room shall be located at entrance of ground floor of the building, other requirements of the system shall be made conforming I.S. 2189:2008.
2. Hooters will be sounded in such a manner so that an operation of the Manual Call Point. Hooters will be sounded on the same floor and immediate alternate floor.
3. Public Address System linked between all floors and Control Room shall have to be established.

AIR CONDITIONING SYSTEM (if any):

1. The A.H.U. shall be separated for each floor with the system. Air Ducts for individual floors.
2. Arrangement shall be made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning System.
3. The system of auto shut down of A.H.U. shall be incorporated with the Auto Detection and Alarm System.
4. The Air Handling Units room shall not be used for storage of any combustible. First Aid Fire Fighting arrangement in the style of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.

GENERAL RECOMMENDATIONS

1. Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.
2. Fire control room to be established at the ground floor.
3. CC TV to be installed in the building.
4. Assembly area shall be specified in the ground floor area.
5. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
6. Floor numbers and directional sign of escape route shall be displayed prominently.
7. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
8. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.
9. A crew of trained Fireman under the experienced Fire Officer shall be maintained round the clock for safety of the building.
10. Mock Fire practice and Evacuation Drill shall be performed periodically with participation of all occupants of the building.
11. A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

On compliance of all the above Fire and Life Safety Recommendation, the Director General, West Bengal Fire & Emergency Services shall be approved for necessary inspection and testing of all the installation, Fire Safety Certificate in favor of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

3. The width and height of the access gate into the premises shall not be less than 4.5 mts. and 5.0 mts. respecting the abutting road.
4. Drive way should be free from any type of obstruction. No parking will be allowed on the drive way.
5. All the Passage way should be kept clear for free access.

STAIRCASE:

1. The staircase of the building shall be enclosed type. Entire construction shall be made of bricks/R.C.C. type having Fire Resisting capacity not less than 4 hours.
2. The staircase of the building shall have permanent vents at the top and operable sashes at each floor level in the external walls of the building.
3. The width of the staircase shall be made as shown in the plan. Corridors and the exit doors shall conform the relevant Building Rules with up to date amendment.

LIFT(if any):

1. The walls of the lift enclosure shall be at least two hours Fire Resisting type.
2. Collapsible gate shall not be permitted.

FIRE FIGHTING WATER:

Underground water reservoir having water capacity of 20000 ltrs. and overhead water reservoir having capacity of 20000 ltrs. exclusively for firefighting purpose with replenishing arrangements @ 1000 ltrs/min. preferably from two different sources of water supply shall be provided. The water reservoirs shall have overflow arrangement with the domestic water reservoir (if any) as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

HYDRANT SYSTEM:

1. The building shall be provided with Down corner of 100 mm. internal diameter pipe line with provision of twin landing valves at the staircase landings/half landings at the rate of one such riser for 1000 sqm. of floor area. The system shall be so designed that shall be kept charged with water all the time in auto mode with providing the one electric pump with the capacity 450 lpm & one stand by pump have same capacity as stand by pump of pressure and capable to discharge 450 ltrs./min. at the ground level outlet and at the top most outlet. In both cases the running pressure shall not be less than 3.5 kgs/sq.cm. All other requirements shall conforming I.S. 3844-1969.
2. Provision for Hose Reel in conjunction with wet Riser shall be made at each floor level and conforming the relevant I.S. Specifications.
3. Yard Hydrant/Ring Main Hydrant with provision of adequate numbers hydrant with one number of Fire Service Inlet shall be installed surrounding the building in accordance with relevant I.S. specifications.

ELECTRICAL INSTALLATION AND DISTRIBUTION:

1. The electrical installation including Transformers, Switch Gear, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire Safety in general building as laid down in I.S. specification 1946-1982.
2. The vertical and horizontal electrical ducts shall be sealed at each floor level by fire resisting materials.
3. The electrical installation shall be adequately protected with CO2/D.C.P. Fire Extinguishers conforming I.S. specification.
4. Arrangement for alternative power supply shall have to be made to supply power with the help of a generator to operate at least the Fire Pump, Deep Tube-Well Pump, Fire Alarm System etc. and also for illuminating the Staircase, Corridor.



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no..FSR/0125186221200035

Date: 22-03-2022

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: Biswanath Institute of B.Ed College
VIII-Mojlispur, P.O.-Pairachali, Falta Road, South 24 Parganas, Pin-743503

Sub: Fire Safety Recommendation for an existing B.Ed. College Building of G + II storied under group occupancy Educational Building in the name & style "Biswanath Institute of B.Ed College" at the Plot no. 665,702,704,705,701/1243 Mouza- Mojlispur , JL no.- 77, VIII-Mojlispur, P.O.-Pairachali, Falta Road, South 24 Parganas, Pin-743503

This is in reference to your application no. 0125186221200035 dated 02-02-2022 regarding the Fire Safety Recommendation for an existing B.Ed. College Building of G + II storied under group occupancy Educational Building in the name & style "Biswanath Institute of B.Ed College" at the Plot no. 665,702,704,705,701/1243 Mouza- Mojlispur , JL no.- 77, VIII-Mojlispur, P.O.-Pairachali, Falta Road, South 24 Parganas, Pin-743503

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

CONSTRUCTION:

- 1.The whole construction of the building shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipality Body
- 2.The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
- 3.Provision of ventilation at the crown of the central core-duct of the building shall be provided
- 4.Arrangement shall have to be made for sealing all the vertical and horizontal ducts by the materials of adequate fire resisting capacity.

OPEN SPACE AND APPROACH:

- 1.The open spaces surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire Appliances with turning facility.
- 2.The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting 45M.T.